

**STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT**



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-15263 Name of Facility: Carver, G. W. Md. Address: 4901 Lincoln Drive City, Zip: Coconut Grove 33133  Type: Public Schools Owner: M-DCSB Food and Nutrition Person In Charge: Shelley Stroleny PIC Email: strolenys@dadeschools.net	<b>Correct By: Next Inspection</b> <b>Re-Inspection Date: None</b>
Phone: 305-444-7388	

**Inspection Information**

Purpose: Routine Inspection Date: 2/3/2020	Begin Time: 02:10 PM End Time: 03:00 PM
---	--

**Additional Information**

FEMALES ..... 523 MALES ..... 482	CENSUS ..... 1005
--------------------------------------	-------------------

*This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

**Violation Markings**

SCHOOL SANITATION <u>IN</u> 1. School Site <u>IN</u> 2. Playground, Equip & Athletic Fields* <u>IN</u> 3. Athletic & Playground Equipment BUILDING CONST/MAINT. <u>IN</u> 4. Construction <u>OUT</u> 5. Maintenance & Repair <u>IN</u> 6. Lighting Standards <u>IN</u> 7. Heating, Ventilation, A/C Standards <u>IN</u> 8. Natural Ventilation <u>IN</u> 9. Mechanical Ventilation SANITARY FACILITIES <u>IN</u> 10. Provided/Accessible/Separation	<u>IN</u> 11. Group Toilet Rooms <u>IN</u> 12. Toilet Facilities <u>IN</u> 13. Handwashing Facilities <u>IN</u> 14. Soap Dispensers <u>IN</u> 15. Shower Facilities <u>IN</u> 16. Showers Water Temperatures WATER SUPPLY <u>IN</u> 17. Approved Source <u>IN</u> 18. Drinking Fountains LIQUID WASTE & WASTE WATER <u>IN</u> 19. Sewage Disposal <u>IN</u> 20. Solid Waste PEST CONTROL	<u>IN</u> 21. Pest Control SAFETY <u>IN</u> 22. First Aid Kit DIAPER CHANGING STATION <u>NA</u> 23. Sanitizers <u>NA</u> 24. Changing Station & Mats <u>NA</u> 25. Hand Sink <u>NA</u> 26. Garbage Can ANIMAL HEALTH & SAFETY <u>NA</u> 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES <u>NA</u> 28. Maintenance/Complaint <u>NA</u> 29. Other
---	--	---

*Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation*

*Violation Key: \* = 2. Playground, Equipment & Athletic Fields*

**Inspector Signature:**

**Client Signature:**

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**General Comments**

Satisfactory

Email Address(es): tequigley@dadeschools.net;  
strolenys@dadeschools.net;  
jaybolton@dadeschools.net;  
jware@dadeschools.net;  
ipalacios@dadeschools.net

**Violations Comments**

Violation #5. Maintenance & Repair

-Provide missing tiles on girls restrooms door entrance #02-009.

-Adjust not functional faucet in boys restroom #110 located inside of cubible toilet.

-Replace light bulb burned-out inside of classroom #205 and #306.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Lucia Gonzalez Melendez (913031)  
Inspector Contact Number: (786) 676-2013  
Print Client Name: Carver, G. W. Md.  
Date: 2/3/2020

Inspector Signature:

Handwritten signature of Lucia Gonzalez Melendez.

Client Signature:

Handwritten signature of G. W. Carver.